



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005
www.jaxport.com

August 26, 2021

ADDENDUM NO. 04
TO
SPECIFICATIONS AND CONTRACT DOCUMENTS
FOR
INVITATION TO BID
SSA JACKSONVILLE CONTAINER TERMINAL
CONTAINER YARD IMPROVEMENTS
JPA CONTRACT NO. C-1772

The item(s) of this Addendum shall modify and become a part of the contractual documents for this project as of this date. (Failure to acknowledge this addendum will be grounds for rejection of proposal.)

ATTACHMENTS TO CONTRACT SPECIFICATIONS

Attachment No. 01
Response to Question

Acknowledgment of the following addenda is hereby made:

Addendum #4, Dated: _____ Initials _____

Company _____

NOTE: THIS ADDENDUM SHALL BE ACKNOWLEDGED IN YOUR BID SUBMISSION, FAILURE TO ACKNOWLEDGE ADDENDUM WILL BE GROUNDS FOR REJECTION OF BID.

PLEASE VISIT <http://www.jaxport.com/procurement/active-solicitations> OR CALL THE PROCUREMENT DEPARTMENT AT (904) 357-3017, PRIOR TO THE BID OPENING TO DETERMINE IF ANY ADDENDA HAVE BEEN RELEASED ON THIS CONTRACT.



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005

INVITATION TO BID

**JPA CONTRACT NO.: C-1772
SSA JACKSONVILLE CONTAINER TERMINAL – CONTAINER YARD IMPROVEMENTS**

RESPONSE TO QUESTIONS

1. There seems to be some confusion regarding the type of base to be used for the project. Our vendors are telling us some contractors are asking for Limerock Base and others are asking for GAB (Graded Aggregate Base). Limerock Base refers to FDOT Section 285. GAB refers to FDOT Section 204. The Pavement Details on sheet 79 specifically indicate FDOT Section 204 which is Graded Aggregate Base. However, JPA refers to Limerock Base in the Solicitation on page ITB-1. There is a substantial price difference between the 2 products. Please clarify

ANSWER:

Technical Specification Section 32 11 23 Aggregate Base and Subbase Courses states in Paragraph 2.01 BASE COURSE "A. As specified for Graded Aggregate Base, Group 1, in Section 204 of the FDOT Standard Specifications."

Section 204 of FDOT Standard Specifications states, "Group 1: This group of aggregates is composed of limestone, marble, or dolomite." Limerock is crushed limestone, and shall meet the quality of Section 911. Section 285 does not provide the grading of the base, but refers to Section 204.

Drawing 001-C-5301 Detail 1 shows the pavement cross section and states, "Limestone Graded Aggregate Base as per FDOT Section 204". Final "Issued for Construction" Drawings will state Limerock instead of Limestone to avoid confusion.

Thus, the drawings and specifications are consistent, and it is confirmed that the pavement base shall be limerock, as typically used in Florida.