



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005
www.jaxport.com

September 9, 2021

ADDENDUM NO. 08
TO
SPECIFICATIONS AND CONTRACT DOCUMENTS
FOR
INVITATION TO BID
SSA JACKSONVILLE CONTAINER TERMINAL
CONTAINER YARD IMPROVEMENTS
JPA CONTRACT NO. C-1772

The item(s) of this Addendum shall modify and become a part of the contractual documents for this project as of this date. (Failure to acknowledge this addendum will be grounds for rejection of proposal.)

ATTACHMENTS TO CONTRACT SPECIFICATIONS

ATTACHMENT NO. 1
Response to Questions

Acknowledgment of the following addenda is hereby made:

Addendum #8, Dated: _____ Initials _____

Company _____

NOTE: THIS ADDENDUM SHALL BE ACKNOWLEDGED IN YOUR BID SUBMISSION, FAILURE TO ACKNOWLEDGE ADDENDUM WILL BE GROUNDS FOR REJECTION OF BID.

PLEASE VISIT <http://www.jaxport.com/procurement/active-solicitations> OR CALL THE PROCUREMENT DEPARTMENT AT (904) 357-3017, PRIOR TO THE BID OPENING TO DETERMINE IF ANY ADDENDA HAVE BEEN RELEASED ON THIS CONTRACT.



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005

INVITATION TO BID

**JPA CONTRACT NO.: C-1772
SSA JACKSONVILLE CONTAINER TERMINAL – CONTAINER YARD IMPROVEMENTS**

RESPONSE TO QUESTIONS

1. We do not see any new permanent security fence called for in the plans. Is there any new security fence required on this project? If so, please provide drawings and specifications.

ANSWER:

To ensure ongoing security of the terminal throughout construction it is intended that existing security fences on the perimeter of the terminal remain, unless shown to be demolished on the Drawings. Any damage to existing security fences caused by the Contractor shall be repaired at Contractor's cost. Details of typical security gate and security fence are provided on Drawings Site. Temporary accesses of this nature would require approval of Tenant and Construction Manager. The security fence would be reinstated per the Drawing details when use of the temporary gate is no longer required by the Contractor. The pavement edge shall be 12 inches from the inside of the existing security fence for purposes of the bid.