



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005
www.jaxport.com

September 10, 2021

ADDENDUM NO. 09
TO
SPECIFICATIONS AND CONTRACT DOCUMENTS
FOR
INVITATION TO BID
SSA JACKSONVILLE CONTAINER TERMINAL
CONTAINER YARD IMPROVEMENTS
JPA CONTRACT NO. C-1772

The item(s) of this Addendum shall modify and become a part of the contractual documents for this project as of this date. (Failure to acknowledge this addendum will be grounds for rejection of proposal.)

ATTACHMENTS TO CONTRACT SPECIFICATIONS

ATTACHMENT NO. 1

Response to Question(s)

Acknowledgment of the following addenda is hereby made:

Addendum #9, Dated: _____ Initials _____

Company _____

NOTE: THIS ADDENDUM SHALL BE ACKNOWLEDGED IN YOUR BID SUBMISSION, FAILURE TO ACKNOWLEDGE ADDENDUM WILL BE GROUNDS FOR REJECTION OF BID.

PLEASE VISIT <http://www.jaxport.com/procurement/active-solicitations> OR CALL THE PROCUREMENT DEPARTMENT AT (904) 357-3017, PRIOR TO THE BID OPENING TO DETERMINE IF ANY ADDENDA HAVE BEEN RELEASED ON THIS CONTRACT.



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005

INVITATION TO BID

**JPA CONTRACT NO.: C-1772
SSA JACKSONVILLE CONTAINER TERMINAL
CONTAINER YARD IMPROVEMENTS**

RESPONSE TO QUESTIONS

1. We received Addendum #5 it pertains to the High Mast Light Poles, but it also depicts a new hydrant detail. It is very different than the standard detail within the Utility details and Specs. Which detail are we to bid/construct?

ANSWER:

The Bid shall be based on the Drawings and Specifications. Fire hydrants shall be based on details on Bid Drawing 001-C-5802. Reference K is provided "For Reference Only" as guidance of typical HMLP foundations for manufacturer's design, as stated in Addendum No.5.