



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005
www.jaxport.com

April 16, 2024

ADDENDUM NO. 01
TO
SPECIFICATIONS AND CONTRACT DOCUMENTS
FOR
INVITATION TO BID
DPMT AUGUST DRIVE ROAD IMPROVEMENTS
JPA CONTRACT NO. C-1957

The item(s) of this Addendum shall modify and become a part of the contractual documents for this project as of this date.
(Failure to acknowledge this addendum will be grounds for rejection of proposal.)

ATTACHMENTS TO CONTRACT SPECIFICATIONS

Attachment No. 1 – Questions received by E-mail and/or E-Builder

Acknowledgment of the following addenda is hereby made:

Addendum #1, Dated: _____ Initials _____

Company _____

NOTE: THIS ADDENDUM SHALL BE ACKNOWLEDGED IN YOUR BID SUBMISSION, FAILURE TO ACKNOWLEDGE ADDENDUM WILL BE GROUNDS FOR REJECTION OF BID.

PLEASE VISIT <http://www.jaxport.com/procurement/active-solicitations> PRIOR TO THE BID OPENING TO DETERMINE IF ANY ADDENDA HAVE BEEN RELEASED ON THIS CONTRACT.



Post Office Box 3005
2831 Talleyrand Avenue
Jacksonville, Florida 32206-0005

INVITATION TO BID

**DPMT AUGUST DRIVE ROAD IMPROVEMENTS
JPA CONTRACT NO. C-1957**

**ADDENDUM NO. 01
RESPONSE TO QUESTIONS**

1. During the Pre-Construction Meeting (held 04/09/24), in the overview of the scope of work, activities and estimated quantities were stated. Please include these items in the addendum as confirmation.

ANSWER: The approximate lengths/quantities stated in the pre-bid are as follows:

1. 156 ft of transitional overlay
2. 400 ft of 9-inch overlay
3. 175 ft of milling and resurfacing (2")
4. Demolish and install 150 ft of curb and gutter